


## UKCA Declaration of Performance

<b>UK CA</b>	
<b>Notified Body</b>	2797
Teal Products Ltd, 8a Orchard Industrial Estate, Toddington, Cheltenham, GL54 5EB, UK	
<b>Product Code</b>	SCP-500 SCP-800
<b>Intended Use</b>	Electrical control system for smoke ventilation systems.
<b>System</b>	System 1
<b>Harmonised Standard</b>	EN 12101-10
<b>Operation Class</b>	A
<b>Environmental Class</b>	1
<b>IP Rating</b>	IP 30
<b>Interruption Time</b>	1 Second
<b>Minimum Standby Period</b>	72 Hours
<b>Maximum Capacity</b>	7Ah
<b>Input</b>	230v AC (+/- 10%) 50/60Hz
<b>Output Current</b>	SCP-500 = 5A SCP-800 = 8A
<b>Output Voltage</b>	24V DC
<b>Teal Products Ltd</b>	 Sam Yiend, Managing Director 8a Orchard Industrial Estate, Toddington, Cheltenham, GL54 5EB, UK
<b>Declaration Number</b>	UKCA-SCP-500-800-2023-1